

FIELD REPORT

PROJECT 1120 MARTIN ST. JOB No. _____
THE CHUK RESIDENCE DATE AUG 9/10
Go JEFF. T. / TERRY SCHULZ


REF: FOUNDATION INSPECTIONS (3RD)

REMARKS & APPROVED REBAR

- ① 4 - 12" dia. CONCRETE SONAR TUBES AT ~~THE~~ SCREWPILES. (DECK)
- ② BALANCE OF UNDERPIN AT SOUTH & EAST WILL ELEV.
- ③ RETAINING WALL AT NW
- ④ 1 - PAD FTR. FOR SE DECK.

OKAY TO POUR BRCK.

NOTIFY FOR INSPECTIONS FOR EAST RETAINING
WALL REINFORCEMENT.



For: CONTRACTOR

For: LUIZ LEON & ASSOCIATES LTD.

ANY CORRECTIVE WORK NOTED ABOVE REQUIRES THE IMMEDIATE ATTENTION OF THE CONTRACTOR AND CONSTITUTES WRITTEN INSTRUCTIONS TO BRING THE WORK INTO CONFORMITY WITH THE PLANS AND SPECIFICATIONS AT NO EXTRA COST TO THE OWNER. THIS SHALL NOT BE CONSTRUED AS A COMPLETE LIST NOR SHALL IT RELIEVE THE CONTRACTOR FROM THE RESPONSIBILITY FOR THE PROPER PERFORMANCE OF HIS WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.