

CITY OF VANCOUVER

452 WEST 12TH
VANCOUVER, B.C. V5Y 1V4
TEL : 604-873-7595 FAX : 604-873-7100

DATE ISSUED JANUARY 20, 2009		PERMIT TYPE FIRE PREVENTION DIVISION PERMIT			PERMIT NUMBER P FI 406645	
LEGAL DESCRIPTION Lot 4 Blk 151 Plan 1947 DL 264A LD NW				ADDRESS 2123 E 8TH AV		
ADDITIONAL ADDRESS INFORMATION						
APPROXIMATE DATE JAN 20, 2009	PURPOSE REMOVAL	PROJECT VALUE	ASSESSED VALUE	PLANS	NET/ACC NO	PLACE NAME
TEMPORARY PERMIT DATES		TEMPORARY USE DATES		SUBTYPE		
APPLICANT CONTRACTOR NORTH SHORE OIL TANK RECOVERY DOUGLAS FROST 711 - 1641 LONSDALE AV NORTH VANCOUVER BC V7M 2J5			CONTACT 2		CONTACT 3	
TEL 604-788-1488 FAX	BUS. LICENSE CERTIFICATE	451018	TEL FAX	BUS. LICENSE CERTIFICATE	TEL FAX	BUS. LICENSE CERTIFICATE

PURSUANT TO THE FIRE BY-LAW, THE FOLLOWING WORK IS HEREBY AUTHORIZED:

TO REMOVE 1 TANK ON SITE. CAPACITY IS 625 GALS. SETBACK IS 6'. BOTTOM OF TANK AT 72".

PERMIT CONDITIONS AND NOTES:

- 001 THE WORK UNDER THIS PERMIT IS AUTHORIZED PURSUANT TO THE FIRE BY-LAW.
- 010 For fuel dispensing site or known contamination site, clearance from Environmental Protection Branch.
- 025 If the work cannot be completed in the same day, the owner must follow the requirements of Section 8.2 of the Vancouver Building By-law for Protection of the Public and Fire Safety on fencing off construction sites.
- 030 For removal: the tanks, together with connected piping and dispensing equipment, shall have all combustible or flammable liquids removed. The tanks and piping must be removed from the ground and purged of vapours. The pipe ends must be permanently sealed by capping or plugging.
- 040 Tank removal must comply with subsection 4.10.3 of the Vancouver Fire By-law.
- 046 Written verification from applicant after work is completed to:
Attention: Customer Service Lieutenant, 201-456 W Broadway, Vancouver, B.C., V5Y 1R3
- 051 Phone the District Fire Inspector at 604-873-7595 for an inspection prior to backfilling. Please arrange for the inspection at least 24 hours in advance.

GENERAL USE	SPECIFICS/LOCATION	AREA (SF)	OCC	GENERAL USE	SPECIFICS/LOCATION	AREA (SF)	OCC
D30	ONE-FAM DWELLING						

ITEM	SPECIFICS/REFERENCE	QTY/AMT	ITEM	SPECIFICS/REFERENCE	QTY/AMT
OIL TANK		1 TANK			

DOCUMENTS REQD BEFORE PERMIT IS COMPLETED INCLUDE : FIRE COMPLETION
 APPROVALS REQD BEFORE PERMIT IS COMPLETED INCLUDE : FIRE INSPECTION

*Tank removed
Jan 21/09
[Signature]*

AS OWNER OR OWNERS' AGENT, I HAVE VERIFIED THAT THE INFORMATION CONTAINED WITHIN THIS DOCUMENT AND ASSOCIATED PLANS IS CORRECT, AND DESCRIBES A USE, A BUILDING OR A WORK WHICH COMPLIES WITH ALL RELEVANT BY-LAWS AND STATUTES. I ACKNOWLEDGE THAT RESPONSIBILITY FOR BY-LAW COMPLIANCE RESTS WITH THE OWNER AND THE OWNER'S EMPLOYEES, AGENTS AND CONTRACTORS. I WILL INDEMNIFY AND SAVE HARMLESS THE CITY OF VANCOUVER, ITS OFFICIALS, EMPLOYEES AND AGENTS AGAINST ALL CLAIMS, LIABILITIES AND EXPENSES OF EVERY KIND, IN RESPECT OF ANYTHING DONE OR NOT DONE PURSUANT TO THIS APPLICATION OR FACT SHEET OR ISSUING PERMIT, INCLUDING NEGLIGENCE AND/OR THE FAILURE TO OBSERVE ALL BY-LAWS, ACTS OR REGULATIONS.

FEE	AMOUNT	FEE	AMOUNT	SIGNATURE DATE ISSUED BY C BAWN. FOR THE FIRE CHIEF
666 TANK - SFD	300.00			
INVOICE: 534258				
TOTAL		\$300.00		

PSD2000.01 REVISED FEB/05